

Declaration of Conformity

Degree of protection provided by enclosure (IP code)

With this letter we confirm that independent LED drivers from eldoLED with ENEC certification according to standard IEC613471-1 (lamp control gear) have undergone an additional test on degrees of protection provided by the enclosure (IP Code). The standard IEC 61347-1 for independent usage requires an additional test related to standard IEC 60598-1 (luminaires), which confirms a minimum ingress protection of IP20. If a different IP class is executed, this will be visual on the label.

Issued by:

eldoLED B.V.

Place, date:

Son, 08/10/2020

Signature of authorized person:



Geert Sesink
Development Manager